



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Enti esterni

Mese DICEMBRE-2020

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		140		150		9		
1	0	*		*		*		*		*
2	0	*		*		*		*		*
3	0	*		*		*		*		*
4	12	44,19	100	65,55	100	109,24	100	8,11	100	13.583.086,15
5	24	0,55	100	95,64	100	99,46	100	4,47	100	26.288.753,34
6	0	*		*		*		*		*
7	0	*		*		*		*		*
8	0	*		*		*		*		*
9	0	*		*		*		*		*
10	0	*		*		*		*		*
11	20	0	100	108,15	100	98,78	100	4,09	100	22.980.602,15
12	24	3,22	100	114,76	100	95,16	100	3,96	100	29.653.358,01
13	24	0	100	95,24	100	100,88	100	3,66	100	27.045.422,44
14	24	2,09	100	113,95	100	117,13	100	3,14	100	29.384.629,52
15	24	0,44	100	104,27	100	103,54	100	3,39	100	29.555.299,32
16	24	0,03	100	110,65	100	121,27	100	3,38	100	30.441.636,82
17	0	*		*		*		*		*
18	0	*		*		*		*		*
19	0	*		*		*		*		*
20	0	*		*		*		*		*
21	0	*		*		*		*		*
22	0	*		*		*		*		*
23	0	*		*		*		*		*
24	0	*		*		*		*		*
25	0	*		*		*		*		*
26	0	*		*		*		*		*
27	0	*		*		*		*		*
28	0	*		*		*		*		*
29	0	*		*		*		*		*
30	0	*		*		*		*		*
31	0	*		*		*		*		*
Valore Mese	176	3,88	100	103,28	100	105,60	100	4,02	100	208.932.787,75

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------