



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3
 Tabella Medie Giornaliere per Enti esterni
 Mese APRILE-2021

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmo	id %	mg/Nmo	id %	mg/Nmo	id %	mg/Nmo	id %	Nmo
Limite applicabile		150		140		150		9		
1	0	*		*		*		*		*
2	0	*		*		*		*		*
3	0	*		*		*		*		*
4	0	*		*		*		*		*
5	0	*		*		*		*		*
6	0	*		*		*		*		*
7	0	*		*		*		*		*
8	0	*		*		*		*		*
9	0	*		*		*		*		*
10	0	*		*		*		*		*
11	0	*		*		*		*		*
12	0	*		*		*		*		*
13	0	*		*		*		*		*
14	13	0	100	85,42	100	112,98	100	5,81	100	14.540.318,97
15	19	0,10	100	112,41	100	127,44	100	5,18	100	22.057.441,15
16	0	*		*		*		*		*
17	0	*		*		*		*		*
18	0	*		*		*		*		*
19	20	0	100	111,82	100	121,13	100	3,70	100	21.987.978,91
20	24	0	100	115,37	100	94,21	100	3,74	100	28.088.018,88
21	24	0,18	100	108,13	100	108,43	100	5,02	100	25.974.750,72
22	11	0	100	117,28	100	125,20	100	5,13	100	12.078.555,91
23	0	*		*		*		*		*
24	0	*		*		*		*		*
25	0	*		*		*		*		*
26	0	*		*		*		*		*
27	0	*		*		*		*		*
28	0	*		*		*		*		*
29	0	*		*		*		*		*
30	0	*		*		*		*		*
Valore Mese	111	N.A.	100	N.A.	100	N.A.	100	N.A.	100	122.725.084,34

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------