



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3
 Tabella Medie Giornaliere per Enti esterni
 Mese AGOSTO-2017

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	0	*		*		*		*		*
2	0	*		*		*		*		*
3	13	85,36	100	112,87	100	122,18	100	6,85	100	19.762.230,41
4	24	62,80	100	132,47	100	136,63	100	7,19	100	39.252.670,60
5	24	30,05	100	127,85	100	126,60	100	5,53	100	32.059.311,19
6	24	13,05	100	131,69	100	128,13	100	5,00	100	29.457.526,96
7	24	47,84	100	131,89	100	120,85	100	4,73	100	35.425.771,67
8	16	60,95	100	130,62	100	120,97	100	6,37	100	23.697.378,88
9	18	77,61	100	130,57	100	124,46	100	5,49	100	27.355.194,89
10	23	63,60	100	126,85	100	125,72	100	4,71	100	32.564.902,17
11	0	*		*		*		*		*
12	0	*		*		*		*		*
13	0	*		*		*		*		*
14	0	*		*		*		*		*
15	0	*		*		*		*		*
16	0	*		*		*		*		*
17	0	*		*		*		*		*
18	0	*		*		*		*		*
19	0	*		*		*		*		*
20	0	*		*		*		*		*
21	0	*		*		*		*		*
22	0	*		*		*		*		*
23	0	*		*		*		*		*
24	0	*		*		*		*		*
25	0	*		*		*		*		*
26	0	*		*		*		*		*
27	0	*		*		*		*		*
28	11	77,74	100	136,08	100	134,73	100	6,25	100	15.902.632,94
29	24	93,70	100	126,06	100	121,34	100	7,31	100	39.571.169,91
30	24	86,12	100	133,39	100	121,89	100	5,77	100	39.111.689,33
31	24	87,22	100	148,80	100	121,90	100	6,42	100	39.596.300,86
Valore Mese	249	62,81	100	131,30	100	125,28	100	5,91	100	373.756.779,59

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
-----------------------------------	-----------------------------	---------------------------------