



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3
 Tabella Medie Giornaliere per Enti estemi
 Mese GIUGNO-2017

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	0	*		*		*		*		*
2	0	*		*		*		*		*
3	0	*		*		*		*		*
4	0	*		*		*		*		*
5	0	*		*		*		*		*
6	0	*		*		*		*		*
7	0	*		*		*		*		*
8	0	*		*		*		*		*
9	0	*		*		*		*		*
10	0	*		*		*		*		*
11	0	*		*		*		*		*
12	0	*		*		*		*		*
13	24	6,39	100	53,10	100	132,07	100	2,91	100	23.988.396,65
14	22	4,47	100	46,35	100	114,62	100	2,97	100	21.694.952,44
15	0	*		*		*		*		*
16	0	*		*		*		*		*
17	0	*		*		*		*		*
18	0	*		*		*		*		*
19	13	6,20	100	44,21	100	117,23	100	2,81	100	14.656.563,95
20	0	*		*		*		*		*
21	0	*		*		*		*		*
22	16	13,70	100	129,93	100	132,68	100	3,32	100	21.695.026,11
23	0	*		*		*		*		*
24	0	*		*		*		*		*
25	0	*		*		*		*		*
26	18	22,03	100	77,17	100	120,93	100	4,07	100	22.846.370,88
27	24	50,04	100	113,62	100	107,84	100	4,75	100	35.722.058,64
28	24	52,70	100	117,20	100	112,11	100	5,16	100	34.266.336,63
29	24	45,65	100	128,29	100	117,29	100	5,74	100	34.453.675,56
30	24	23,89	100	97,36	100	108,79	100	5,17	100	29.353.415,96
Valore Mese	189	26,89	100	91,49	100	117,56	100	4,22	100	238.676.796,85

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------