



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Enti esterni

Mese SETTEMBRE-2021

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		140		150		9		
1	0	*		*		*		*		*
2	0	*		*		*		*		*
3	0	*		*		*		*		*
4	0	*		*		*		*		*
5	0	*		*		*		*		*
6	0	*		*		*		*		*
7	0	*		*		*		*		*
8	0	*		*		*		*		*
9	0	*		*		*		*		*
10	0	*		*		*		*		*
11	0	*		*		*		*		*
12	0	*		*		*		*		*
13	0	*		*		*		*		*
14	0	*		*		*		*		*
15	0	*		*		*		*		*
16	20	9,11	100	82,24	100	88,97	100	4,57	100	24.200.726,23
17	24	46,39	100	106,02	100	95,83	100	4,83	100	32.572.892,22
18	24	48,83	100	109,00	100	99,36	100	5,50	100	33.216.313,49
19	24	31,87	100	120,37	100	117,91	100	6,47	100	32.268.076,57
20	24	5,98	100	109,90	100	108,50	100	4,52	100	29.749.739,63
21	24	8,76	100	111,31	100	118,33	100	5,66	100	30.560.205,66
22	24	14,99	100	113,94	100	119,00	100	6,05	100	29.676.035,18
23	24	9,12	100	119,14	100	113,49	100	6,00	100	29.736.716,21
24	19	12,60	100	115,66	100	126,66	100	4,93	100	24.194.108,22
25	0	*		*		*		*		*
26	0	*		*		*		*		*
27	0	*		*		*		*		*
28	0	*		*		*		*		*
29	0	*		*		*		*		*
30	0	*		*		*		*		*
Valore Mese	207	21,28	100	110,12	100	109,78	100	5,42	100	266.174.813,41

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------