



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Enti esterni

Mese DICEMBRE-2018

Dati Ricalcolati NAS

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	24	18,91	100	110,37	100	140,46	100	0,16	100	33.910.904,16
2	24	64,82	100	143,41	100	128,37	100	0,05	100	37.178.168,22
3	24	51,10	100	128,09	95,83	147,04	95,83	0,47	100	34.758.025,37
4	24	66,08	91,67	126,88	91,67	140,48	91,67	0	100	37.822.385,31
5	24	54,65	95,83	139,84	95,83	136,27	95,83	0,03	100	37.913.533,18
6	24	52,98	100	133,46	100	135,07	100	0,17	100	37.545.349,94
7	24	69,19	100	133,13	100	130,05	100	0,04	100	37.593.755,66
8	24	31,62	100	130,57	100	137,21	100	0	100	33.588.381,45
9	24	15,88	100	139,77	100	135,04	100	0	100	31.613.442,04
10	24	68,01	100	138,81	100	132,47	100	0	100	37.458.657,61
11	24	78,60	100	152,56	100	129,79	100	0,16	100	40.706.357,96
12	24	36,21	100	154,06	100	132,33	100	0,17	100	36.886.731,33
13	24	58,35	100	146,84	100	136,57	100	0	100	37.269.427,75
14	24	58,21	100	153,00	100	142,26	100	0,02	100	38.962.498,15
15	24	14,09	100	143,87	100	145,41	100	0	100	32.716.450,93
16	24	41,78	100	144,26	100	144,35	100	0,01	100	37.435.061,42
17	24	43,70	100	138,27	100	141,96	100	0,05	100	37.185.309,68
18	24	35,21	100	156,18	100	138,99	100	0,02	100	37.451.955,96
19	24	43,09	100	132,95	100	140,46	100	0,30	100	37.084.629,69
20	24	42,75	100	140,60	100	135,85	100	0,21	100	35.826.388,97
21	24	29,03	100	125,74	100	134,62	100	0,16	100	33.031.693,42
22	0	*		*		*		*		*
23	0	*		*		*		*		*
24	0	*		*		*		*		*
25	0	*		*		*		*		*
26	0	*		*		*		*		*
27	0	*		*		*		*		*
28	0	*		*		*		*		*
29	0	*		*		*		*		*
30	0	*		*		*		*		*
31	0	*		*		*		*		*
Valore Mese	504	46,30	99,4	138,77	99,21	137,35	99,21	0,10	100	763.939.108,20

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------