



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Enti esterni

Mese DICEMBRE-2021

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		NH3 nor		HG nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		140		150		9		5		0,10		
1	0	*		*		*		*		*		*		*
2	0	*		*		*		*		*		*		*
3	0	*		*		*		*		*		*		*
4	0	*		*		*		*		*		*		*
5	0	*		*		*		*		*		*		*
6	0	*		*		*		*		*		*		*
7	0	*		*		*		*		*		*		*
8	0	*		*		*		*		*		*		*
9	0	*		*		*		*		*		*		*
10	0	*		*		*		*		*		*		*
11	0	*		*		*		*		*		*		*
12	0	*		*		*		*		*		*		*
13	0	*		*		*		*		*		*		*
14	8	1,97	100	91,63	100	117,49	100	5,58	100	0,33	100	0,000122	100	9.974.221,43
15	24	0,61	100	100,38	100	112,50	100	6,49	100	0,31	100	0,000120	100	31.105.802,79
16	24	26,20	100	97,11	100	113,06	100	6,51	100	0,20	100	0,000101	100	32.654.680,76
17	24	19,61	100	102,09	100	113,90	100	7,26	100	0,18	100	0,000094	100	30.921.414,56
18	24	23,55	100	107,21	100	113,55	100	7,64	100	0,17	100	0,000091	100	30.809.448,37
19	24	25,33	100	108,95	100	112,28	100	6,71	100	0,18	100	0,000096	100	30.563.657,86
20	24	8,40	100	122,45	100	111,26	100	8,44	100	0,28	100	0,000143	100	27.841.356,95
21	24	34,55	100	128,33	100	106,19	100	7,30	100	0,37	100	0,000141	100	27.392.465,10
22	0	*		*		*		*		*		*		*
23	0	*		*		*		*		*		*		*
24	0	*		*		*		*		*		*		*
25	0	*		*		*		*		*		*		*
26	0	*		*		*		*		*		*		*
27	0	*		*		*		*		*		*		*
28	0	*		*		*		*		*		*		*
29	0	*		*		*		*		*		*		*
30	0	*		*		*		*		*		*		*
31	0	*		*		*		*		*		*		*
Valore Mese	176	18,94	100	108,69	100	112,08	100	7,12	100	0,25	100	0,000113	100	221.263.047,81

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------