



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Enti esterni

Mese DICEMBRE-2016

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	24	62,05	100	134,10	100	153,41	100	7,34	100	42.024.783,75
2	24	78,19	100	152,31	100	148,85	100	7,96	100	43.103.721,13
3	24	79,27	100	148,69	100	145,83	100	8,50	100	41.722.866,38
4	24	28,73	100	127,97	100	149,71	100	7,06	100	33.002.006,75
5	24	38,75	100	140,16	100	141,96	100	5,11	100	39.364.931,13
6	24	30,38	100	135,78	100	119,72	100	5,86	100	42.354.485,75
7	24	43,88	100	146,52	100	139,81	100	4,94	100	42.058.189,25
8	24	35,49	100	142,46	100	151,37	100	4,61	100	36.459.630,25
9	24	54,05	100	146,70	100	147,69	100	4,70	100	39.856.497,63
10	24	32,50	100	144,02	100	147,95	100	4,23	100	37.264.752,50
11	24	49,61	100	132,08	100	144,12	100	4,80	100	38.314.588,13
12	24	65,66	100	117,71	100	144,14	100	5,84	100	38.645.142,25
13	8	30,57	100	115,58	100	141,96	100	6,63	100	11.991.233,25
14	0	*		*		*		*		*
15	0	*		*		*		*		*
16	0	*		*		*		*		*
17	0	*		*		*		*		*
18	0	*		*		*		*		*
19	0	*		*		*		*		*
20	24	72,39	100	138,55	100	140,18	100	5,52	100	37.906.399,75
21	24	65,05	100	144,92	100	142,16	100	5,95	100	39.147.002,13
22	24	57,79	100	137,22	100	150,90	100	6,56	100	39.496.615,75
23	24	19,02	100	133,63	100	157,17	100	4,78	100	38.224.347,75
24	24	9,12	100	133,09	100	152,05	100	3,83	100	31.385.572,88
25	24	8,49	100	99,68	100	140,92	100	3,74	100	31.248.790,63
26	24	16,03	100	112,41	100	140,35	100	4,01	100	33.404.348,88
27	24	19,14	100	131,22	100	135,40	100	4,08	100	39.625.094,38
28	24	22,32	100	126,60	100	134,86	100	4,30	100	38.553.797,25
29	24	38,76	100	137,46	100	130,43	100	4,28	100	39.511.121,38
30	24	41,96	100	123,55	100	129,23	100	4,33	100	42.337.159,38
31	24	20,11	100	125,91	100	130,68	100	5,66	100	38.145.434,75
Valore Mese	584	41,05	100	133,61	100	142,45	100	5,35	100	935.148.513,00

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------