



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Mese

Mese FEBBRAIO-2017

Giorno	Ore di Normale Funzionamento	CO nor		SO2 nor		NOx nor		POLV nor		O2	
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Misurato vol%	Ref. vol%
Limite applicabile		150		180		180		15			
1	24	77,06	100	131,70	100	126,18	100	10,05	100	8,41	6,00
2	24	56,00	100	132,19	100	125,78	100	8,81	100	8,71	6,00
3	24	94,32	100	139,56	100	126,56	100	9,70	100	8,81	6,00
4	24	80,73	100	134,81	100	127,72	100	9,42	100	8,92	6,00
5	24	95,05	100	135,54	100	126,73	100	9,19	100	8,76	6,00
6	24	62,38	100	129,16	100	126,94	100	11,31	100	8,39	6,00
7	24	54,36	100	123,06	100	127,44	100	9,93	100	8,24	6,00
8	24	62,00	100	123,72	100	126,47	100	11,55	100	8,00	6,00
9	24	64,79	100	123,72	100	126,54	100	11,66	100	7,87	6,00
10	24	83,29	100	129,07	100	124,56	100	10,81	100	8,40	6,00
11	24	67,48	100	133,88	100	118,79	100	10,48	100	8,68	6,00
12	24	61,75	100	134,80	100	126,69	100	8,66	100	8,78	6,00
13	24	52,69	100	132,78	100	124,33	100	9,19	100	8,72	6,00
14	24	43,36	100	118,55	100	120,30	100	8,78	100	8,30	6,00
15	24	47,41	100	113,50	100	125,23	100	9,05	100	8,52	6,00
16	24	39,00	100	115,09	100	122,96	100	10,28	100	8,41	6,00
17	24	61,71	100	139,69	100	122,27	100	9,80	100	8,58	6,00
18	6	25,26	100	129,04	100	124,88	100	11,65	100	9,20	6,00
19	0	*		*		*		*		*	*
20	0	*		*		*		*		*	*
21	0	*		*		*		*		*	*
22	0	*		*		*		*		*	*
23	0	*		*		*		*		*	*
24	0	*		*		*		*		*	*
25	21	14,17	100	145,20	100	122,32	100	9,07	100	9,16	6,00
26	24	26,04	100	131,81	100	123,35	100	10,13	100	8,92	6,00
27	24	80,46	100	133,23	100	123,10	100	10,98	100	9,04	6,00
28	24	62,55	100	130,33	100	121,96	100	9,26	100	8,55	6,00
Valore Medio	507	61,12	100	129,96	100	124,60	100	9,94	100	8,58	6,00

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------