



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3  
 Tabella Medie Giornaliere per Enti esterni  
 Mese NOVEMBRE-2021

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		NH3 nor		HG nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		140		150		9		5		0,10		
1	0	*		*		*		*		*		*		*
2	0	*		*		*		*		*		*		*
3	0	*		*		*		*		*		*		*
4	0	*		*		*		*		*		*		*
5	0	*		*		*		*		*		*		*
6	0	*		*		*		*		*		*		*
7	0	*		*		*		*		*		*		*
8	0	*		*		*		*		*		*		*
9	0	*		*		*		*		*		*		*
10	0	*		*		*		*		*		*		*
11	0	*		*		*		*		*		*		*
12	0	*		*		*		*		*		*		*
13	0	*		*		*		*		*		*		*
14	0	*		*		*		*		*		*		*
15	0	*		*		*		*		*		*		*
16	12	4,09	100	71,83	100	96,39	100	3,87	100	0,33	100	0	100	13.401.735,14
17	24	4,15	100	92,09	100	124,90	100	3,14	100	0,24	100	0	100	27.188.996,78
18	24	4,97	100	101,89	100	123,48	100	3,45	100	0,28	100	0	100	28.442.615,28
19	20	4,59	100	92,24	100	125,41	100	3,51	100	0,24	100	0	100	23.942.651,65
20	0	*		*		*		*		*		*		*
21	0	*		*		*		*		*		*		*
22	0	*		*		*		*		*		*		*
23	0	*		*		*		*		*		*		*
24	2	N.A.	100	N.A.	100	N.A.	100	N.A.	100	N.A.	100	N.A.	100	2.298.830,55
25	13	10,60	100	94,49	100	119,45	100	3,72	100	0,40	100	0	100	16.564.273,89
26	0	*		*		*		*		*		*		*
27	0	*		*		*		*		*		*		*
28	0	*		*		*		*		*		*		*
29	0	*		*		*		*		*		*		*
30	0	*		*		*		*		*		*		*
Valore Mese	95	N.A.	100	N.A.	100	N.A.	100	N.A.	100	N.A.	100	N.A.	100	111.839.103,29

N.A. Media non applicabile      N.D. Non disponibile      \* Media non valida x VLE