



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Enti esterni

Mese GIUGNO-2019

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	0	*		*		*		*		*
2	0	*		*		*		*		*
3	0	*		*		*		*		*
4	0	*		*		*		*		*
5	0	*		*		*		*		*
6	0	*		*		*		*		*
7	0	*		*		*		*		*
8	0	*		*		*		*		*
9	0	*		*		*		*		*
10	0	*		*		*		*		*
11	0	*		*		*		*		*
12	0	*		*		*		*		*
13	0	*		*		*		*		*
14	0	*		*		*		*		*
15	0	*		*		*		*		*
16	0	*		*		*		*		*
17	0	*		*		*		*		*
18	0	*		*		*		*		*
19	0	*		*		*		*		*
20	0	*		*		*		*		*
21	0	*		*		*		*		*
22	0	*		*		*		*		*
23	0	*		*		*		*		*
24	14	5,11	100	43,39	100	123,99	100	1,07	100	16.278.450,54
25	24	64,11	100	94,15	100	145,35	100	1,84	100	35.300.688,08
26	24	60,94	100	156,28	100	122,22	100	3,03	100	37.557.677,84
27	24	61,45	100	144,68	100	125,06	100	1,21	100	35.300.711,58
28	24	69,37	100	153,28	100	124,69	100	0,79	100	36.587.457,11
29	23	14,67	100	132,97	100	128,80	100	0,26	100	27.449.001,39
30	0	*		*		*		*		*
Valore Mese	133	N.A.	100	N.A.	100	N.A.	100	N.A.	100	188.473.986,55

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------