



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Enti esterni

Mese LUGLIO-2019

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	0	*		*		*		*		*
2	18	74,10	100	147,05	100	125,08	100	0,80	100	28.535.905,42
3	24	58,64	100	140,27	100	124,97	100	0,92	100	36.844.228,27
4	24	49,29	100	127,40	100	126,43	100	0,89	100	35.466.489,83
5	24	42,21	100	132,41	100	128,03	100	0,82	100	33.526.285,75
6	24	19,09	100	132,50	100	136,40	100	1,10	100	28.545.478,88
7	7	6,24	100	113,71	100	132,74	100	1,35	100	7.480.336,65
8	0	*		*		*		*		*
9	0	*		*		*		*		*
10	0	*		*		*		*		*
11	0	*		*		*		*		*
12	0	*		*		*		*		*
13	0	*		*		*		*		*
14	0	*		*		*		*		*
15	0	*		*		*		*		*
16	0	*		*		*		*		*
17	0	*		*		*		*		*
18	0	*		*		*		*		*
19	0	*		*		*		*		*
20	0	*		*		*		*		*
21	0	*		*		*		*		*
22	0	*		*		*		*		*
23	0	*		*		*		*		*
24	15	4,13	100	132,59	100	112,79	100	0,18	100	16.191.382,48
25	24	25,56	100	143,38	100	144,11	100	0,95	100	29.699.428,54
26	23	58,84	100	134,57	100	142,75	100	1,03	100	30.714.695,14
27	0	*		*		*		*		*
28	0	*		*		*		*		*
29	0	*		*		*		*		*
30	0	*		*		*		*		*
31	0	*		*		*		*		*
Valore Mese	183	40,81	100	135,25	100	131,12	100	0,89	100	247.004.230,94

N.A. Media non applicabile

N.D. Non disponibile

\* Media non valida x VLE