



**Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3**  
 Tabella Medie Giornaliere per Enti esterni  
 Mese SETTEMBRE-2019

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	0	*		*		*		*		*
2	14	9,91	100	118,31	100	136,50	100	1,62	100	20.419.166,19
3	24	6,16	100	140,85	100	143,78	100	1,30	100	34.021.050,12
4	24	11,15	100	137,17	100	145,97	100	2,51	100	33.332.556,47
5	24	34,24	100	142,35	100	146,35	100	2,49	100	34.120.672,25
6	22	34,82	100	135,21	100	134,29	100	1,17	100	30.088.787,74
7	0	*		*		*		*		*
8	0	*		*		*		*		*
9	0	*		*		*		*		*
10	0	*		*		*		*		*
11	0	*		*		*		*		*
12	0	*		*		*		*		*
13	0	*		*		*		*		*
14	0	*		*		*		*		*
15	0	*		*		*		*		*
16	0	*		*		*		*		*
17	0	*		*		*		*		*
18	0	*		*		*		*		*
19	0	*		*		*		*		*
20	0	*		*		*		*		*
21	0	*		*		*		*		*
22	0	*		*		*		*		*
23	0	*		*		*		*		*
24	0	*		*		*		*		*
25	0	*		*		*		*		*
26	0	*		*		*		*		*
27	0	*		*		*		*		*
28	0	*		*		*		*		*
29	0	*		*		*		*		*
30	0	*		*		*		*		*
Valore Mese	108	N.A.	100	N.A.	100	N.A.	100	N.A.	100	151.982.232,77

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------